



U.S. NPSM / NPT THREAD UNITS				
SIZE	NOMINAL FLOW RANGE	L Fraction [mm]	W Fraction [mm]	H Fraction [mm]
5/8 x 1/2"	1-10 GPM	7-1/2"	3-45/64"	4-15/64"
	0.13-1.34 ft <sup>3</sup> /min	[190mm]	[94mm]	[107.5mm]
5/8 x 3/4"	1-20 GPM	7-1/2"	3-45/64"	4-15/64"
	0.13-2.67 ft <sup>3</sup> /min	[190mm]	[94mm]	[107.5mm]
3/4"	2-30 GPM	7-35/64"	3-13/16"	4-3/4"
	0.27-4.01 ft <sup>3</sup> /min	[191.5mm]	[96.84mm]	[120.65mm]
1"	3-50 GPM	10-1/4"	3-55/64"	4-5/8"
	0.4-6.68 ft <sup>3</sup> /min	[260mm]	[98mm]	[117.50mm]
1-1/4"	3-50 GPM	10-1/4"	3-55/64"	4-5/8"
	0.4-6.68 ft <sup>3</sup> /min	[260mm]	[98mm]	[117.50mm]
1-1/2"	5-100 GPM	11-13/16"	4-51/64"	5-9/16"
	0.67-13.37 ft <sup>3</sup> /min	[300mm]	[122mm]	[141.5mm]
2"	80-160 GPM	11-13/16"	5-45/64"	6-31/32"
	10.69-21.39 ft <sup>3</sup> /min	[300mm]	[145mm]	[177mm]
U.K. BSPP / BSPT THREAD UNITS				
SIZE	NOMINAL FLOW RANGE	L Fraction [mm]	W Fraction [mm]	H Fraction [mm]
15mm	0.12-1.5 m <sup>3</sup> /hr	6-1/2"	3-45/64"	4-15/64"
	0.12-1.5 KL/hr	[165mm]	[94mm]	[107.5mm]
15x20mm	0.12-1.5 m <sup>3</sup> /hr	7-1/2"	3-45/64"	4-15/64"
	0.12-1.5 KL/hr	[190mm]	[94mm]	[107.5mm]
20mm	0.2-2.5 m <sup>3</sup> /hr	7-1/2"	3-45/64"	4-15/64"
	0.2-2.5 KL/hr	[190mm]	[94mm]	[107.5mm]
25mm	0.25-3.5 m <sup>3</sup> /hr	10-1/4"	3-55/64"	4-5/8"
	0.25-3.5 KL/hr	[260mm]	[98mm]	[117.50mm]
32mm	0.48-6 m <sup>3</sup> /hr	10-1/4"	3-55/64"	4-5/8"
	0.48-6 KL/hr	[260mm]	[98mm]	[117.50mm]
40mm	0.8-10 m <sup>3</sup> /hr	11-13/16"	4-51/64"	5-9/16"
	0.8-10 KL/hr	[300mm]	[122mm]	[141.5mm]
50mm	1.2-15 m <sup>3</sup> /hr	11-13/16"	5-45/64"	6-31/32"
	1.2-15 KL/hr	[300mm]	[145mm]	[177mm]

R2-700990-00

			DATE	NAME	MATERIAL
			DWN BY	ARTWORK WM2 SERIES MULTI-JET WATER METER (FOR REFERENCE ONLY)	FINISH
			CHKD		<b>DWYER INSTRUMENTS, INC.</b> MICHIGAN CITY, INDIANA 46360 U.S.A.
			APPD		
NO.	CHANGES	BY/DATE			ACAD2002
<small>NOTICE: This drawing and the principles and elements of design embodied therein are the exclusive property of DWYER INSTRUMENTS, INC. and are not to be communicated, disclosed, reproduced or used except as previously authorized in writing by such corporation and must not be submitted to outside parties for examination without the written consent of said corporation.</small>					3